


RAYCHEM

TraceTek

TT1100-0HP

WATER SENSING CABLE FOR SUSPENDED PIPE INSTALLATION INSTRUCTIONS



TOOLS REQUIRED

Wire cutters	Used to cut off tie wrap ends
TT-PTB-1000 (PN 486437-000)	Portable Test Box, battery powered instrument designed for testing and troubleshooting TraceTek systems
Digital multimeter	Can be used as an alternative or supplement to the PTB. Meter must have 20 $\mbox{M}\mbox{\Omega}$ range
TT-MAPPING CAP-PC (PN P000000872)	Used to simulate leaks at connector points during commissioning and mapping process
Extra TT-MLC-PC (PN 683262-000)	Leader cable. Used with the ohmmeter to make easier connections to the sensor cable for resistance measurements
Extra TT-MET-PC (PN 169905-000)	End termination. Used during installation or trouble shooting to temporarily isolate a sub-section of sensor cable for resistance measurements

DESCRIPTION

These Instructions explain the proper procedures for installing and testing nVent RAYCHEM TraceTek TT1100-OHP sensing cables. TT1100-OHP sensing cables are primarily intended for use on overhead piping to detect a water leak originating from a small pin hole or crack in the pipe. The wicking action of the absorptive synthetic fiber outerbraid on the TT1100-OHP cable can catch and hold a small drip or trickle of water— to ensure sufficient wetted length to generate a leak alarm. TT1100-OHP can also be used on floors, in drip pans, in sumps and trenches and similar flat surface applications, however TT1000 standard water detection cable may be better suited to flat surfaces.

Important Notes

When used to monitor suspended or rack mounted pipe, TT1100-OHP sensing cables must be attached to the pipe at the lowest point where any water leak is most likely to drip from the pipe system. This will be the 6 o'clock position on horizontal piping but other mounting locations and techniques may be necessary if site conditions are unusual. In particular, special consideration should be given to pipe supports, couplings, "T's", valves and other fittings. It is the responsibility of the installer to position the cable such that any leak will drip onto the cable.

The sensor cable cannot stop a leak. In some installations the materials or structures beneath the pipe system may be so critical or valuable, that a drip tray system should be considered in addition to the sensor cable installation. TT1100-OHP is intended to alert the user that a pipe or system is leaking but it cannot prevent collateral damage if the leak is not contained and repaired immediately.

ADDITIONAL MATERIALS REQUIRED

Supplied by installer and sized to go around the pipe and sensor cable. Base quantity on one tie wrap per foot (0.3 m) for horizontal run with extra wraps at
fittings.
Use to wipe and clean bottom and side surfaces of pipe prior to cable installation.

OPTIONAL MATERIALS

TT-MBC-PC (PN 847529-000)	Branch connector used to connect and branch "T" lines
TT-MJC-xx-PC	This jumper cable is available in various pre-cut and terminated lengths
TT-1100-OHP-CK-PC-M/F (PN P000001186)	Connector kit used during field connections of TT1100-OHP bulk cable

GENERAL NOTES: DO'S AND DON'TS:

DO:

- Store the cable in its original container in a clean, dry area until ready to install.
- · Clean the pipe surface where the cable will be installed.
- Schedule the sensor cable installation as late as possible in the construction schedule to avoid risk of damage or contamination by other contractors or construction tasks.
- Remove cable from the pipe if any thread cutting, welding, soldering or similar pipe fitting work will be performed.

DON'T:

- Drag the cable through water, paint, solvents, oil or other contaminants.
- · Install damaged or contaminated sensing cable.
- Allow the cable to become wet or contaminated after installation.
- Exceed the maximum pulling force of 100 kg (220 lb)
- Use the cable as a rope for lifting or securing any object.
- · Allow tools or heavy objects to fall on cable.
- Exceed 3300 ft (1000 m) sensor cable circuit length


Installation

1

Clean and prepare the pipe or area where the cable will be installed

- 1. Verify that major construction is complete.
 - Clean the bottom and sides of the pipe where the cable will be installed to remove any residual waste or contamination.
 - If the cable will be placed in drip trays, make sure to wipe the surface of the drip tray and remove any liquids or debris.
 - For sumps, containment trenches, and subfloor applications, install TraceTek hold-down clips. For TraceTek TT1100-OHP series sensing cables, use 1/2 inch (13 mm) hold-down clips (TT-HDC-1/2-NA-50).
 - Clean the floor surface where hold-down clips will be placed so adhesive can work properly.
 - Position hold-down clips so the sensing cable will provide the desired leak detection coverage. To best secure the cable, alternate the direction of the hold-down clips, and install them at intervals of no greater than 6 feet (2 m) and at every change in direction (at sides of trench, for example).

Important: Let the adhesive dry per manufacturer's recommendation before proceeding with sensing cable installation.



2

Check each length of sensing cable before installation.

 To ensure that each length of sensing cable is intact and free of contamination, follow the Sensing Cable Test Procedure.
 Do not use damaged or contaminated sensing cable.



3

Observe proper precautions when handling sensing cables.

 Observe the do's and don'ts under "General Notes" on page 1 of these instructions; take care to avoid damaging or contaminating sensing cable.





Connect, orient, install, and test each length of sensing cable in sequence

- Connect a Modular End Termination (TT-MET-PC) to the first sensingcable length to be installed.
- 2. Orient sensing cable so the connector used with the end termination will be the furthest away from connection to the TraceTek alarm module. Work out from the alarm module connection. For sensing cable on reels (lengths over 10 feet (3 m)), put the reel on an axle and pull the cable out.
- 3. **Install** sensing cable in accordance with the leak detection layout plan. A. For pipeline applications:
 - Position the cable along the bottom of the pipe and use tie wraps to secure the cable at the 6 o'clock position. Maintain cable position within 1/4 inch (6 mm) of 6 o'clock position.
 - Tie wraps should be long enough to go around the pipe and the sensor cable.
 - Use one tie wrap every 12 in to 18 in (300 to 450 mm) along the pipe with extra tie wraps at fittings or bends as needed.

Important: It is the installer's responsibility to position the sensor cable correctly. The cable must trace the lowest point of the pipe or fittings such that any water leaking from the pipe or fittings will drip onto the cable surface as it drips off the bottom of the pipe or fitting. Do not install the cable on the top or side surface of a pipe. Do not spiral the cable on horizontal pipe.

Exception: If the cable is used to trace vertical pipe, the cable should be spiraled around the pipe and secured with tie-wraps.


- B. For sumps, containment trenches, and subfloor applications:
 - Pull the cable alongside the installed hold-down clips; minimum bend radius is 2 in (50 mm). Leave 6 in (150 mm) of sensing cable on each end for the connector service loop.

Important: Verify that the adhesive securing the hold-down clips has dried; liquid adhesive must not contact the cable. Push sensing cable into the hold-down clips and position the sensing cable to lay flat on the surface to be monitored. Secure by snapping hold-down clip end into base.

- 4. Test each length of sensing cable after installing it and before attaching it to cable already installed. Confirm that the sensing cable is clean and intact by following the Sensing Cable Test Procedure.
- 5. **Connect** the sensing cable to the cable string (lengths of sensing cable connected in series) previously installed.

For sumps, containment trenches, and subfloor applications:

- · Leave a service loop at each connector as shown.
- · Mark the connector position on the layout plan.
- · Install TraceTek mapping tag (TT-TAG).
- Note: As an extra precaution on large installations, periodically test the entire cable string to confirm that all installed sensing cable is still clean and intact.
- Unplug the end termination and connect it to the next length of sensing cable to be installed.
- 6. Repeat the installation sequence for each length of cable.




Complete the system

 Install other TraceTek components (such as Modular Branching Connectors, Weighted Lengths, and Modular Jumper Cables) as called for in the system layout. Complete the sensing circuit.

Note: All components of the system have male or female metal connectors or both. The male connectors are oriented toward the instrument panel. As new sections of cable are added to the main leg or branch, each newly added section should end with an open female connector. The end of each branch or main leg is terminated with a male end termination.

- Test the sensing circuit (or portions of it) to confirm that the sensing cable is clean and intact. Follow the Sensing Cable Test Procedure.
- Connect the sensing circuit to the TraceTek alarm module and activate the system as soon as is practical. Use the alarm module to monitor the sensing cable during the final stages of construction.



6


Take precautions if installation is incomplete at end of work day.

At the end of the work day:

- Ensure that there are no open connectors. Each sensing cable should be connected to a Modular Leader Cable (TT-MLC-PC), Modular End Termination (TT-MET-PC), and/or other sensing cables; check both ends of the cable.
- Test and record the condition of installed sensing cable following the Sensing Cable Test Procedure.
- If practical, connect the installed sensing cable to the TraceTek alarm module. Test the system and put it in operation following the alarm module installation instructions.

At the beginning of the next work day:

 Check that the installed sensing cable is clean and intact following the Sensing Cable Test Procedure. Compare the results with those obtained at the end of the previous work day. If necessary, investigate and correct problems before proceeding.







Sensing Cable Test Procedure

Method with TraceTek Portable Text Box (PTB)

- 1. Ensure the end termination is connected to the sensing cable. If checking several lengths of sensing cable in series (a cable string), ensure they are all connected.
- 2. Connect the PTB to the sensing cable(s) using its adapter, as illustrated.
- 3. Verify that the sensing cable is intact; follow the operating instructions printed inside the lid of the PTB itself. If a cable or connection is broken, the PTB illuminates its LED indicating "cable break," and displays a "1" in the leftmost position of its LCD display. If the cable string is intact, the PTB measures the system length.
 - · If the cable string is not intact, apply this test procedure to segments of the system to identify the open connection or damaged modular length.
 - Note: If a heat-shrink tube must be removed to access a connector, refer to Oversleeve Removal Instructions (H54258).
- 4. Check the condition of the sensing cable(s), again following the PTB operating instructions. If the sensing cables are clean and free of contamination, the current measured should be below 10 µA. If the reading exceeds 10 µA, use the PTB to locate the liquid or contamination and take appropriate corrective action.





Method with Ohmmeter

- 1. Ensure the end termination is connected to the sensing cable. If checking several lengths of sensing cable in series (a cable string), ensure they are all connected.
- 2. Connect a Modular Leader Cable (TT-MLC-PC) to the sensing
- 3. Verify that the sensing cable is intact:
 - · Loop 1: Measure the resistance between the yellow and black wires of the leader cable as illustrated.
 - Loop 2: Measure the resistance between the red and green wires of the leader cable.

The readings should roughly equal a multiple of the length of sensing cable:

3.9 times the length of sensing cable or 12.8 times the length of sensing cable.

Example: 3.9 x 50 ft of cable $= 195 \Omega$ 12.8 x 15 m of cable = 192 Ω


In addition, the resistance of the two loops should be within 5 percent of each other.


If the cable string is not intact, apply this test procedure to segments of the system to identify the open connection or damaged modular length.

Note: If a heat-shrink tube must be removed to access a connector, refer to Oversleeve Removal Instructions (H54258).

4. Check the condition of the sensing cable. Measure the resistance between the black and green wires of the leader cable.

If the reading is below 20 megohms, apply this test procedure to segments of the system to identify the modular sensing cable length(s) affected, locate the liquid or contamination, and take appropriate corrective action.






Complete System Connections and Layout

- A.TT1100-OHP is available in a variety of pre-cut and terminated lengths. Each cable has a female plastic connector on one end and a male plastic connector on the opposite end. Cable sections plug together like extension cords.
- B. (Optional) A branch connector (TT-MBC-PC) is used to connect and branch "T" lines. The branch connector has one male connector and two female connectors. For mapping purposes, the cable connected to the center leg of the branch connector will be counted first, then the distance measurements will continue from the second female connector and continue along the rest of the system. A dead band of 15 ft (5 m) is inserted at the beginning and end of each branch to avoid any location ambiguity.
- C. (Optional) It is permissible to have TT-MBCs installed on branches as needed to fully trace a pipe system.
- D. Install an end termination (TT-MET-PC) at the end of the main line and each branch line. (Note: A good check on the system design and bill of materials is that the total number of end terminations installed in the system should equal the number of branch connectors plus one)


- E. (Optional) Install jumper cables (TT-MJC-xxx-PC) as needed to connect sensing cable sections if they are spatially separated. Jumper cable is available in various pre-cut and terminated lengths and is also available in bulk form for long distance runs between the sensor cable and the instrumentation point.
- F. Install a leader cable (TT-MLC-PC) between the sensor cable and the monitoring instrument. The factory standard length of leader cable is 12 ft (4 m). It has a female plastic connector on one end and four tinned leads on the opposite end for connection at the instrument's sensor cable terminal block. In some installations the distance between the instrument and the start of the sensor cable run will be much greater than 12 feet. In those cases a simple solution is to purchase a jumper cable of sufficient length, then cut off and discard the male connector and any extra cable. Bulk jumper cable and connector kits are also available for lengths that exceed the longest available pre-cut jumper cable.
- G. Use tie-wraps to neatly coil and secure any excess sensor cable, jumper cable, branch connectors, etc.



Initial Power-up and Test

Connect the cable to the selected instrument and test the


- Apply power to the TraceTek instrument and look for a "Normal" indication.
 - On TTC-1, TTSIM-1A or TTSIM-2 family, there will be a green LED and no other red or vellow LEDs. (On TTSIM-1A and TTSIM-2 the green LED will flicker off every 10 seconds.)
 - On TTSIM-1, Normal Condition is indicated by a steady green LED and a momentary flash of the RED LED every 10 seconds.
 - On TTDM-128 the alpha-numeric display will indicate a channel number and display the words SYSTEM NORMAL.
- If the Yellow LED is on in any of these instruments or the words "Cable Break" or "Loop Break" is displayed, then the cable system must be inspected for loose connections, missing end terminations until the cable continuity is established and the "Normal" condition is achieved.
- · LEAK testing can be done with a mapping cap (TT-MAPPING CAP-PC). The MAPPING CAP simulates a leak at the location where it is inserted into the system.
 - For TTC-1, TTSIM-1 and TTSIM-2 a red LED will indicate that the simulated LEAK has been detected.
 - For TTSIM-2 and TTDM-128 a leak location will be displayed in feet or meters (as selected) in addition to the red LED indication
- For larger piping systems with TTDM-128 or TTSIM-2, the MAPPING CAP should be moved sequentially to each accessible connector. Note the distance displayed on the as-built drawings. This will become the basis for the System Map.
- Create a System Map showing where sensing cables and alarm modules have been installed. The System Map will include the beginning and end of sensing cables, and location of any connections. If using locating alarm modules, the System Map should include distance readings at significant landmarks (beginning and end of system, changes of direction, branches, valves, low points, etc.).





TTC-1 Indications:

LEAK LED Red CABLE BREAK LED Yellow Reset Button Red POWFR I FD Green



TTSIM-1A Indications:

CABLE BREAK SERVICE POWER LED


Red Yellow Yellow Green



TTSIM-2 Indications:

CABLE BREAK SERVICE POWER LED

Red Yellow Yellow Green



TTSIM-1 Indications:

SERVICE **POWER LED**

CABLE BREAK Flashing yellow Flashing yellow Green

Troubleshooting Symptom	Possible Cause and Correction
	System is not powered. Check power wiring. Check circuit breakers that may have been tripped. On TTDM-128 check fuse and replace if necessary.
Leak alarm	This is an indication of a LEAK event.
(TTDM-128 message and red LED) (SIM Red LED ON)	For leak locating modules (TTDM-128 and TTSIM-2): Using leak distance indication and System Map as a guide, investigate system condition, work to locate and repair leak.
	For non-locating modules: Work to locate and repair the leak. (If your system is constructed with multiple sensor cable segments, using an end termination (TT-MET-PC) to break the system into sections can help in locating the leak. Work outward from the alarm module using the end termination to establish a temporary end of the circuit, then sequentially move outward adding one cable segment at a time).
	Once the leak is repaired, remove excess water from sensing cable and synthetic fiber jacket. Typically this will clear the Leak Alarm or LEAK condition (Red LED on SIM).
	In order to clear the Service Req'd (or Service condition), moisture levels on sensor cable and synthetic fiber jacket need to be reduced with further drying.
	Note: When the Service Req'd or SERVICE condition exists (Yellow LED), leak location accuracy is reduced for a new leak.
Yellow LED visible on TTC-1, TTSIM-1A, TTSIM-2 or flashing yellow LED on TTSIM-1	Could be cable break or service indication. Refer to alarm module instructions for more information. For Cable break indication:
	Check for loose connectors, missing end terminations, broken jumper wires or physical damage to the cable. Repair or replace cable if necessary. The TT-MET-PC end termination can be used to isolate a damaged section by working outward from the instrument using the end termination to establish a temporary end of the circuit then sequentially moving outward adding one cable segment at a time.
"SERVICE Req'd" message (TTDM-128 Only)	This is an early warning message from the TTDM-128 panel indicating that the cable is becoming damp, but not yet to the level that constitutes a leak. The TTDM-128 panel may display a location in square brackets. If a location is displayed, that location should be investigated for possible sources of condensation/drips. The square brackets indicated that the leak signal is not strong enough for an accurate location calculation, so the indicated locations may include some error.
Red LED fails to turn off after leak is repaired, and leak alarm reset attempted	Cable and over-braid are still damp. Allow more time for cable to dry or investigate leak site to make sure that water is not pooling under or behind the sensor cable.
Leak location seems inaccurate in actual leak situation	More that one leak may be present or the cable may be damp in several locations. If the system is monitore by a TTDM-128, check the event history to see if there is an earlier indication of a nearby leak or a SERVICE NEEDED message. If necessary use the end termination to break the system into smaller segments and work outward to isolate each leak location in multiple leak scenarios.
Leak locations seem inaccurate or unstable during mapping tests	Make sure that the simulated leak (MAPPING CAP) is kept in place for at least 30 seconds. The location circuitry in the instruments require a steady leak location in order to compute an accurate distance. Removing the simulated leak too quickly induces a random error.

North America

Tel +1.800.545.6258 Fax +1.800.527.5703 thermal.info@nvent.com **Europe, Middle East, Africa**

Tel +32.16.213.511 Fax +32.16.213.604 thermal.info@nvent.com **Asia Pacific**

Tel +86.21.2412.1688 Fax +86.21.5426.3167 cn.thermal.info@nvent.com **Latin America**

Tel +1.713.868.4800 Fax +1.713.868.2333 thermal.info@nvent.com

